

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV)  
published on March 28th 2016, last changed on 3rd January 2018

## Fraport drinking water tank vehicles and delivery

Sampling date 27.03.2018

Donnerstag, 5. April 2018

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 1000*	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-33 clutch pipe delivery	9,2	7,1	0,73	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	9,5	7,9	0,82	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	10,0	7,8	0,60	0	2	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	9,8	7,8	0,75	0	2	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	9,7	7,6	0,75	0	1	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	10,0	8,0	0,68	0	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	9,7	7,0	0,70	1	1	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	9,6	7,9	0,72	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	9,9	7,7	0,75	1	1	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	9,8	7,9	0,75	0	1	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	9,0	7,6	0,62	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	8,9	7,7	0,30	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	9,2	7,6	0,87	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	9,0	7,3	1,09	1	1	0	0	0	0

\* Limit value for sample designations like "Übergabestelle": 20 KBE

**Bemerkungen:**