

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV)
published on March 28th 2016, last changed on 3rd January 2018

Fraport drinking water tank vehicles and delivery

Sampling date 12.12.2018

Dienstag, 18. Dezember 2018

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 1000*	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-34 clutch pipe delivery	11,2	7,5	0,74	0	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	10,9	7,6	1,05	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	12,0	7,7	0,50	1	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	10,5	7,7	0,74	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	11,2	7,9	0,79	0	1	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	8,3	7,7	0,78	0	1	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	11,6	7,8	0,64	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	9,5	7,4	0,79	0	5	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	11,2	7,5	0,69	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	11,2	7,8	0,64	0	0	0	0	0	0
Tank vehicle KWW-46 clutch pipe delivery	7,5	7,8	0,78	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	12,0	7,8	0,71	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	12,3	7,8	0,24	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	11,9	7,7	0,78	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	12,1	7,7	0,47	0	0	0	0	0	0

* Limit value for sample designations like "Übergabestelle": 20 KBE

Bemerkungen: