

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500592804
Report April 2018**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
180291334	Drinking water Delivery Tap 1	26.04.2018	09:10	15,8	colorless, clear	0,22	7,64	0	0	0	0	0	0
180291335	Drinking water Delivery Tap 2	26.04.2018	09:35	15,9	colorless, clear	<0,03	7,66	0	0	0	0	0	0
180291336	Drinking water Delivery Tap 3	26.04.2018	09:45	15,5	colorless, clear	0,57	7,63	0	0	0	0	0	0
180291337	Drinking water Delivery Tap 4	26.04.2018	-	-	-	-	-	sampling not possible: tap is defective					
180291338	Tank vehicle KWW 33, clutch pipe delivery	26.04.2018	08:25	16,8	colorless, clear	0,79	7,71	0	0	0	0	0	0
180291339	Tank vehicle KWW 34, clutch pipe delivery	26.04.2018	08:10	16,9	colorless, clear	0,74	7,68	0	0	0	0	0	0
180291938	Tank vehicle KWW 35, clutch pipe delivery	26.04.2018	09:10	15,9	colorless, clear	1,14	7,85	0	0	0	0	0	0
180291939	Tank vehicle KWW 36, clutch pipe delivery	26.04.2018	08:15	16,0	colorless, clear	1,84	7,70	0	0	0	0	0	0
180291940	Tank vehicle KWW 37, clutch pipe delivery	26.04.2018	08:20	16,2	colorless, clear	1,31	7,80	0	0	0	0	0	0
180291941	Tank vehicle KWW 38, clutch pipe delivery	26.04.2018	08:30	16,4	colorless, clear	0,78	7,74	0	0	0	0	0	0
180291942	Tank vehicle KWW 39, clutch pipe delivery	26.04.2018	08:45	15,7	colorless, clear	0,76	7,85	0	0	0	0	0	0
180291943	Tank vehicle KWW 40, clutch pipe delivery	26.04.2018	09:25	15,9	colorless, clear	0,95	7,89	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500592804
Report April 2018**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
180291944	Tank vehicle KWW 41, clutch pipe delivery	26.04.2018	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
180291945	Tank vehicle KWW 42, clutch pipe delivery	26.04.2018	08:40	16,2	colorless, clear	0,78	7,91	0	0	0	0	0	0
180291946	Tank vehicle KWW 43, clutch pipe delivery	26.04.2018	08:55	15,2	colorless, clear	0,25	7,81	0	0	0	0	0	0
180291947	Tank vehicle KWW 44, clutch pipe delivery	26.04.2018	09:00	16,1	colorless, clear	1,02	7,66	0	0	0	0	0	0
180291948	Tank vehicle KWW 45, clutch pipe delivery	26.04.2018	08:50	15,1	colorless, clear	0,27	7,99	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, April 30, 2018