

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500592804
Report July 2018**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
180630049	Drinking water Delivery Tap 1	25.07.2018	09:40	20,5	colorless, clear	0,58	7,57	0	0	0	0	4	0
180630050	Drinking water Delivery Tap 2	25.07.2018	09:35	20,1	colorless, clear	0,53	7,62	0	0	0	0	0	0
180630101	Drinking water Delivery Tap 3	25.07.2018	09:25	21,3	colorless, clear	0,38	7,60	0	0	0	0	0	0
180630102	Drinking water Delivery Tap 4	25.07.2018	09:00	20,2	colorless, clear	0,43	7,57	0	0	0	0	0	0
180630103	Tank vehicle KWW 33, clutch pipe delivery	25.07.2018	08:45	24,5	colorless, clear	0,69	7,76	0	0	0	0	0	0
180630104	Tank vehicle KWW 34, clutch pipe delivery	25.07.2018	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
180630105	Tank vehicle KWW 35, clutch pipe delivery	25.07.2018	08:30	20,3	colorless, clear	0,75	7,53	0	0	0	0	0	0
180630106	Tank vehicle KWW 36, clutch pipe delivery	25.07.2018	08:15	21,2	colorless, clear	0,55	7,44	0	0	0	0	0	0
180630107	Tank vehicle KWW 37, clutch pipe delivery	25.07.2018	08:25	23,1	colorless, clear	0,61	7,79	0	0	0	0	0	0
180630108	Tank vehicle KWW 38, clutch pipe delivery	25.07.2018	09:20	24,9	colorless, clear	0,54	7,85	0	0	0	0	0	0
180630109	Tank vehicle KWW 39, clutch pipe delivery	25.07.2018	08:20	23,0	colorless, clear	0,40	7,80	0	0	0	0	0	0
180630110	Tank vehicle KWW 40, clutch pipe delivery	25.07.2018	08:50	61,4	colorless, clear	0,58	7,66	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500592804
Report July 2018**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
180630111	Tank vehicle KWW 41, clutch pipe delivery	25.07.2018	08:30	24,3	colorless, clear	0,95	7,80	0	0	0	0	0	0
180630112	Tank vehicle KWW 42, clutch pipe delivery	25.07.2018	08:50	-	-	-	-	sampling not possible: tank vehicle in repair shop					
180630113	Tank vehicle KWW 43, clutch pipe delivery	25.07.2018	08:40	23,4	colorless, clear	0,57	7,88	0	0	0	0	0	0
180630114	Tank vehicle KWW 44, clutch pipe delivery	25.07.2018	09:15	21,3	colorless, clear	0,56	7,89	0	0	0	0	0	0
180630115	Tank vehicle KWW 45, clutch pipe delivery	25.07.2018	09:25	23,5	colorless, clear	0,53	7,89	0	0	0	0	0	0

Assessment:

According to the investigations of the German Drinking Water Regulation the following parameter of the testing sample **180630049** out of limit value: **Pseudomonas aeruginosa**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, august 02, 2018