

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV)  
published on March 28th 2016, last changed on 3rd January 2018

## Fraport drinking water tank vehicles and delivery

Sampling date 28.03.2019

Mittwoch, 3. April 2019

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 1000*	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-33 clutch pipe delivery	12,1	8,0	0,89	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	10,8	8,0	0,72	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	12,2	7,8	0,75	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	10,9	7,8	0,83	1	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	12,5	8,2	0,81	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	12,1	8,0	0,75	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	12,2	7,9	0,81	1	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	13,4	8,1	0,86	1	1	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	12,0	8,0	0,78	0	0	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	12,4	7,9	0,71	0	0	0	0	0	0
Tank vehicle KWW-46 clutch pipe delivery	12,2	8,0	0,77	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	13,4	7,9	0,66	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	14,1	7,8	1,05	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	13,6	7,9	0,40	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	14,0	8,1	1,66	0	0	0	0	0	0

\* Limit value for sample designations like "Übergabestelle": 20 KBE

**Bemerkungen:**