

**Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV)
published on March 28th 2016, last changed on 3rd January 2018**

Fraport drinking water tank vehicles and delivery

Sampling date 16.12.2019

Donnerstag, 2. Januar 2020

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony	colony	Escherichia	Coliforms	Pseudomonas	Enterococcus
				count at 22°C [KBE/ml] limit value 100*	count at 36°C [KBE/ml] limit value 100	coli [KBE/100ml] limit value 0	[KBE/100ml] limit value 0	aeruginosa [KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-34 clutch pipe delivery	13,2	7,8	0,80	2	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	12,3	7,9	0,52	1	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	11,4	7,8	0,56	0	1	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	12,6	7,9	0,55	0	2	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	12,2	7,9	0,63	1	4	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	12,3	7,9	0,61	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	12,0	7,7	0,56	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	12,8	7,7	0,87	0	0	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	12,0	7,9	0,63	0	0	0	0	0	0
Tank vehicle KWW-46 clutch pipe delivery	12,8	7,9	0,40	1	1	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	13,2	7,7	0,83	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	13,1	7,7	0,97	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	14,0	7,8	0,72	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	13,9	7,7	0,74	0	0	0	0	0	0

* Limit value for sample designations like "Übergabe Zapfstelle": 20 KBE

Bemerkungen: