

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
Report 4289203 (May 2019)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
190449268	Drinking water Delivery Tap 1	02.05.2019	08:20	16,8	colorless, clear	0,79	7,59	0	0	0	0	0	0
190449269	Drinking water Delivery Tap 2	02.05.2019	09:10	16,4	colorless, clear	0,76	7,65	0	0	0	0	0	0
190449270	Drinking water Delivery Tap 3	02.05.2019	09:00	16,0	colorless, clear	0,42	7,63	0	0	0	0	0	0
190449273	Drinking water Delivery Tap 4	02.05.2019	09:15	17,7	colorless, clear	0,49	7,41	0	0	0	0	0	0
190449274	Tank vehicle KWW 33, clutch pipe delivery	02.05.2019	07:45	16,8	colorless, clear	0,70	7,64	0	0	0	0	0	0
190449275	Tank vehicle KWW 34, clutch pipe delivery	02.05.2019	08:10	18,7	colorless, clear	0,43	7,80	0	0	0	0	0	0
190449276	Tank vehicle KWW 35, clutch pipe delivery	02.05.2019	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
190449277	Tank vehicle KWW 36, clutch pipe delivery	02.05.2019	07:55	17,8	colorless, clear	0,51	7,80	0	0	0	0	0	0
190449280	Tank vehicle KWW 37, clutch pipe delivery	02.05.2019	08:35	18,1	colorless, clear	0,46	7,97	0	0	0	0	0	0
190449299	Tank vehicle KWW 38, clutch pipe delivery	02.05.2019	08:30	17,3	colorless, clear	0,50	7,97	0	0	0	0	0	0
190449300	Tank vehicle KWW 39, clutch pipe delivery	02.05.2019	08:40	17,3	colorless, clear	0,50	7,94	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
Report 4289203 (May 2019)



Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
190449401	Tank vehicle KWW 40, clutch pipe delivery	02.05.2019	08:05	16,9	colorless, clear	0,68	7,85	0	0	0	0	0	0
190449402	Tank vehicle KWW 41, clutch pipe delivery	02.05.2019	08:15	19,3	colorless, clear	0,41	7,72	0	0	0	0	0	0
190449403	Tank vehicle KWW 42, clutch pipe delivery	02.05.2019	08:00	19,0	colorless, clear	0,43	7,77	0	0	0	0	0	0
190449404	Tank vehicle KWW 43, clutch pipe delivery	02.05.2019	08:55	17,7	colorless, clear	0,46	7,99	0	0	0	0	0	0
190449405	Tank vehicle KWW 44, clutch pipe delivery	02.05.2019	08:50	18,0	colorless, clear	0,48	7,95	0	0	0	0	0	0
190449406	Tank vehicle KWW 45, clutch pipe delivery	02.05.2019	07:55	16,9	colorless, clear	0,72	7,69	0	0	0	0	0	0
190449407	Tank vehicle KWW 46, clutch pipe delivery	02.05.2019	08:55	17,4	colorless, clear	0,39	8,02	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

i.x. Andra

SGS INSTITUT FRESENIUS GmbH

Tausenstein, May 08, 2019