

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
 Report 4421088 (July 2019)

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
190708202	Drinking water Delivery Tap 1	31.07.2019	09:55	24,5	colorless, clear	0,22	7,59	0	0	0	0	0	0
190708203	Drinking water Delivery Tap 2	31.07.2019	10:00	24,1	colorless, clear	0,09	7,65	0	0	0	0	0	0
190708204	Drinking water Delivery Tap 3	31.07.2019	10:05	24,8	colorless, clear	0,23	7,63	0	0	0	0	0	0
190708205	Drinking water Delivery Tap 4	31.07.2019	10:10	24,5	colorless, clear	0,79	7,41	0	0	0	0	0	0
190708206	Tank vehicle KWW 33, clutch pipe delivery	31.07.2019	09:00	24,3	colorless, clear	0,13	7,64	0	0	0	0	0	0
190708207	Tank vehicle KWW 34, clutch pipe delivery	31.07.2019	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
190708208	Tank vehicle KWW 35, clutch pipe delivery	31.07.2019	09:45	25,0	colorless, clear	0,32	7,76	0	0	0	0	0	0
190708209	Tank vehicle KWW 36, clutch pipe delivery	31.07.2019	08:45	25,3	colorless, clear	0,21	7,68	0	0	0	0	0	0
190708210	Tank vehicle KWW 37, clutch pipe delivery	31.07.2019	09:40	25,2	colorless, clear	0,32	7,84	0	0	0	0	0	0
190708211	Tank vehicle KWW 38, clutch pipe delivery	31.07.2019	08:50	25,0	colorless, clear	0,36	7,87	0	0	0	0	0	0
190708212	Tank vehicle KWW 39, clutch pipe delivery	31.07.2019	08:30	24,3	colorless, clear	0,22	7,75	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
 Report 4421088 (July 2019)

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
190708213	Tank vehicle KWW 40, clutch pipe delivery	31.07.2019	09:25	24,8	colorless, clear	0,26	7,67	0	0	0	0	0	0
190708214	Tank vehicle KWW 41, clutch pipe delivery	31.07.2019	09:10	29,5	colorless, clear	0,19	7,80	0	0	0	0	0	0
190708215	Tank vehicle KWW 42, clutch pipe delivery	31.07.2019	09:35	26,8	colorless, clear	0,30	7,98	0	0	0	0	0	0
190708216	Tank vehicle KWW 43, clutch pipe delivery	31.07.2019	09:05	25,5	colorless, clear	0,25	7,96	0	0	0	0	0	0
190708217	Tank vehicle KWW 44, clutch pipe delivery	31.07.2019	09:20	24,2	colorless, clear	0,38	8,01	0	0	0	0	0	0
190708218	Tank vehicle KWW 45, clutch pipe delivery	31.07.2019	09:15	24,5	colorless, clear	0,26	7,86	0	0	0	0	0	0
190709263	Tank vehicle KWW 46, clutch pipe delivery	31.07.2019	09:30	24,6	colorless, clear	0,12	7,66	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Tausnusstein, august 12, 2019