

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
Report 4510852 (October 2019)**



Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	turbidity	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
191070163	Drinking water Delivery Tap 1	10.10.2019	11:45	18,6	colorless, clear	0,86	7,80	0,2	0	0	0	0	0	0
191070164	Drinking water Delivery Tap 2	10.10.2019	11:40	19,4	colorless, clear	0,82	7,52	0,3	0	0	0	0	0	0
191070165	Drinking water Delivery Tap 3	10.10.2019	11:50	18,0	colorless, clear	1,10	7,60	0,2	0	0	0	0	0	0
191070166	Drinking water Delivery Tap 4	10.10.2019	12:00	18,0	colorless, clear	0,46	7,70	0,1	0	0	0	0	0	0
191070167	Tank vehicle KWW 33, clutch pipe delivery	10.10.2019	11:10	17,4	colorless, clear	0,70	7,60	0,2	0	0	0	0	0	0
191070168	Tank vehicle KWW 34, clutch pipe delivery	10.10.2019	11:15	15,5	colorless, clear	0,36	7,72	0,3	0	0	0	0	0	0
191071253	Tank vehicle KWW 35, clutch pipe delivery	10.10.2019	11:25	18,2	colorless, clear	0,61	7,52	0,2	0	0	0	0	0	0
191071254	Tank vehicle KWW 36, clutch pipe delivery	10.10.2019	11:30	12,6	colorless, clear	0,36	7,79	0,1	0	0	0	0	0	0
191071255	Tank vehicle KWW 37, clutch pipe delivery	10.10.2019	10:38	16,8	colorless, clear	0,36	7,84	0,2	0	0	0	0	0	0
191071256	Tank vehicle KWW 38, clutch pipe delivery	10.10.2019	11:20	18,2	colorless, clear	0,74	7,50	0,2	0	0	0	0	0	0
191071257	Tank vehicle KWW 39, clutch pipe delivery	10.10.2019	10:35	18,4	colorless, clear	0,36	7,70	0,2	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
Report 4510952 (October 2019)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	turbidity	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
191071258	Tank vehicle KWW 40, clutch pipe delivery	10.10.2019	10:25	18,2	colorless, clear	0,70	7,40	0,2	0	0	0	0	0	0
191071259	Tank vehicle KWW 41, clutch pipe delivery	10.10.2019	11:00	17,6	colorless, clear	0,55	7,48	0,2	0	0	0	0	0	0
191071260	Tank vehicle KWW 42, clutch pipe delivery	10.10.2019	10:55	17,0	colorless, clear	0,60	7,58	0,3	0	0	0	0	0	0
191071261	Tank vehicle KWW 43, clutch pipe delivery	10.10.2019	10:45	16,5	colorless, clear	0,56	7,65	0,2	0	0	0	0	0	0
191071262	Tank vehicle KWW 44, clutch pipe delivery	10.10.2019	10:50	16,2	colorless, clear	0,58	7,56	0,2	0	0	0	0	0	0
191071263	Tank vehicle KWW 45, clutch pipe delivery	10.10.2019	11:35	18,0	colorless, clear	0,62	7,68	0,2	0	0	0	0	0	0
191071264	Tank vehicle KWW 46, clutch pipe delivery	10.10.2019	10:30	19,0	colorless, clear	0,60	7,60	0,2	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Tausenstein, October 16, 2019

int. Andia