

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
Report 5083745 (November 2020)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	turbidity	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
201095074	Drinking water Delivery Tap 1	26.11.2020	10:05	15,2	colorless, clear	1,05	7,71	0,3	0	0	0	0	0	0
201095257	Drinking water Delivery Tap 2	26.11.2020	10:25	17,3	colorless, clear	0,48	7,68	0,3	0	0	0	0	0	0
201095258	Drinking water Delivery Tap 3	26.11.2020	10:15	17,9	colorless, clear	1,71	7,73	0,3	0	0	0	0	0	0
201095259	Drinking water Delivery Tap 4	26.11.2020	10:05	15,4	colorless, clear	1,08	7,71	0,3	0	0	0	0	0	0
201095260	Tank vehicle KWW 36, clutch pipe delivery	26.11.2020	09:25	11,8	colorless, clear	1,13	7,81	0,3	0	0	0	0	0	0
201095261	Tank vehicle KWW 38, clutch pipe delivery	26.11.2020	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
201095262	Tank vehicle KWW 39, clutch pipe delivery	26.11.2020	08:45	12,3	colorless, clear	0,71	7,84	0,3	0	0	0	0	0	0
201095263	Tank vehicle KWW 41, clutch pipe delivery	26.11.2020	09:35	13,8	colorless, clear	0,84	7,80	0,3	0	0	0	0	0	0
201095264	Tank vehicle KWW 42, clutch pipe delivery	26.11.2020	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
201095265	Tank vehicle KWW 43, clutch pipe delivery	26.11.2020	08:50	16,1	colorless, clear	0,94	7,98	0,3	0	0	0	0	0	0
201095266	Tank vehicle KWW 44, clutch pipe delivery	26.11.2020	09:00	14,2	colorless, clear	0,58	7,84	0,4	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



Report on the samples being taken by our field service - Your Order No.: BVD-45000648363
Report 5083745 (November 2020)

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	turbidity	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
201095267	Tank vehicle KWW 45, clutch pipe delivery	26.11.2020	09:45	11,0	colorless, clear	1,09	7,95	0,3	0	0	0	0	0	0
201095268	Tank vehicle KWW 46, clutch pipe delivery	26.11.2020	09:15	14,1	colorless, clear	0,71	7,82	0,3	0	0	0	0	0	0
201095270	Tank vehicle KWW 47, clutch pipe delivery	26.11.2020	10:00	8,5	colorless, clear	0,81	7,72	0,2	0	0	0	0	0	0
201095271	Tank vehicle KWW 48, clutch pipe delivery	26.11.2020	08:30	8,4	colorless, clear	0,24	8,01	0,3	0	0	0	0	0	0
201095291	Tank vehicle KWW 49, clutch pipe delivery	26.11.2020	09:50	12,1	colorless, clear	0,73	7,84	0,3	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Tausenstein, December 11, 2020

i. x. Andia