

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
Report 4790817 (May 2020)



Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	turbidity	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
200413558	Drinking water Delivery Tap 1	07.05.2020	11:00	17,4	colorless, clear	1,10	7,80	0,2	0	0	0	0	0	0
200413559	Drinking water Delivery Tap 2	07.05.2020	10:55	17,2	colorless, clear	0,55	7,76	0,2	0	0	0	0	0	0
200413562	Drinking water Delivery Tap 3	07.05.2020	10:40	17,4	colorless, clear	0,66	7,74	0,2	0	0	0	0	0	0
200413563	Drinking water Delivery Tap 4	07.05.2020	10:30	17,6	colorless, clear	0,92	7,72	0,3	0	0	0	0	0	0
200413564	Tank vehicle KWW 36, clutch pipe delivery	07.05.2020	08:50	17,6	colorless, clear	0,62	7,80	0,2	0	0	0	0	0	0
200413565	Tank vehicle KWW 37, clutch pipe delivery	07.05.2020	09:00	16,4	colorless, clear	0,84	7,80	0,2	0	0	0	0	0	0
200413566	Tank vehicle KWW 38, clutch pipe delivery	07.05.2020	08:45	16,4	colorless, clear	0,55	8,00	0,2	0	0	0	0	0	0
200413567	Tank vehicle KWW 39, clutch pipe delivery	07.05.2020	09:15	16,6	colorless, clear	0,58	7,82	0,2	0	0	0	0	0	0
200413568	Tank vehicle KWW 40, clutch pipe delivery	07.05.2020	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
200413569	Tank vehicle KWW 41, clutch pipe delivery	07.05.2020	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
200413570	Tank vehicle KWW 42, clutch pipe delivery	07.05.2020	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
Report 4790817 (May 2020)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	turbidity	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
200413571	Tank vehicle KWW 43, clutch pipe delivery	07.05.2020	10:00	17,0	colorless, clear	0,68	7,88	0,40	0	0	0	0	0	0
200413572	Tank vehicle KWW 44, clutch pipe delivery	07.05.2020	09:20	16,4	colorless, clear	1,25	7,80	1,6	0	0	0	0	0	0
200413573	Tank vehicle KWW 45, clutch pipe delivery	07.05.2020	10:25	17,6	colorless, clear	0,60	7,80	0,4	0	0	0	0	0	0
200413574	Tank vehicle KWW 46, clutch pipe delivery	07.05.2020	10:45	17,8	colorless, clear	1,06	7,74	0,2	0	0	0	0	0	0
200413575	Tank vehicle KWW 47, clutch pipe delivery	07.05.2020	09:30	15,6	colorless, clear	0,60	7,84	0,2	0	1	0	0	0	0
200413576	Tank vehicle KWW 48, clutch pipe delivery	07.05.2020	10:20	17,2	colorless, clear	0,44	7,80	0,3	0	0	0	0	0	0
200413577	Tank vehicle KWW 49, clutch pipe delivery	07.05.2020	09:40	16,2	colorless, clear	0,76	7,80	0,3	0	1	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Tausenstein, May 14, 2020

Andreas