

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV)  
published on March 28th 2016, last changed on 3rd January 2018

## Fraport drinking water tank vehicles and delivery

Sampling date 24.06.2020

Dienstag, 7. Juli 2020

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100*	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-36 clutch pipe delivery	21,7	7,8	0,28	38	159	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	21,8	7,8	0,26	0	40	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	25,0	8,1	0,27	0	15	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	21,8	7,9	0,39	102	248	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	23,5	7,9	0,33	6	2	0	0	0	0
Tank vehicle KWW-47 clutch pipe delivery	24,4	8,4	0,30	5	2	0	0	0	0
Tank vehicle KWW-48 clutch pipe delivery	21,3	7,6	0,78	2	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	20,2	7,8	0,28	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	20,2	7,9	0,56	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	20,6	7,7	0,53	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	20,5	7,7	0,62	4	0	0	0	0	0

\* Limit value for sample designations like "Übergabe Zapfstelle": 20 KBE

### Bemerkungen: