

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500731378
Report 5309578 (May 2021)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	turbidity	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
210430745	Drinking water Delivery Tap 1	27.05.2021	09:55	15,0	colorless, clear	0,74	7,66	1,2	0	0	0	0	0	0
210430746	Drinking water Delivery Tap 2	27.05.2021	09:45	14,6	colorless, clear	0,74	7,66	0,8	0	0	0	0	0	0
210430747	Drinking water Delivery Tap 3	27.05.2021	09:40	15,4	colorless, clear	0,50	7,66	1,1	0	0	0	0	0	0
210430748	Drinking water Delivery Tap 4	27.05.2021	09:35	14,6	colorless, clear	0,74	7,66	1,4	0	0	0	0	0	0
210430749	Tank vehicle KWW 36, clutch pipe delivery	27.05.2021	09:00	14,4	colorless, clear	0,74	7,74	2,2	0	3	0	0	0	0
210430750	Tank vehicle KWW 39, clutch pipe delivery	27.05.2021	08:40	13,4	colorless, clear	0,58	7,80	1,7	0	0	0	0	0	0
210430901	Tank vehicle KWW 39, clutch pipe delivery	27.05.2021	09:30	14,6	colorless, clear	0,90	7,68	1,2	0	0	0	0	0	0
210430902	Tank vehicle KWW 41, clutch pipe delivery	27.05.2021	08:50	14,0	colorless, clear	0,86	7,64	1,2	0	0	0	0	0	0
210430903	Tank vehicle KWW 42, clutch pipe delivery	27.05.2021	-	-	-	-	-	-	sampling not possible: free chlorine >15 mg/l					
210430904	Tank vehicle KWW 43, clutch pipe delivery	27.05.2021	09:10	14,4	colorless, clear	0,72	7,70	1,4	0	0	0	0	0	0
210430905	Tank vehicle KWW 44, clutch pipe delivery	27.05.2021	09:20	14,2	colorless, clear	0,84	7,70	1,2	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500731378
Report 5309578 (May 2021)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	turbidity	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
210430906	Tank vehicle KWW 45, clutch pipe delivery	27.05.2021	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
210430907	Tank vehicle KWW 46, clutch pipe delivery	27.05.2021	08:35	13,8	colorless, clear	0,70	7,70	1,3	0	0	0	0	0	0
210430908	Tank vehicle KWW 47, clutch pipe delivery	27.05.2021	08:38	13,6	colorless, clear	0,66	7,78	0,9	0	0	0	0	0	0
210430909	Tank vehicle KWW 48, clutch pipe delivery	27.05.2021	08:40	12,2	colorless, clear	0,52	7,66	0,4	0	0	0	0	0	0
210430910	Tank vehicle KWW 49, clutch pipe delivery	27.05.2021	08:35	13,4	colorless, clear	0,56	7,94	1,2	0	0	0	0	0	0

Assessment:

According to the investigations of the German Drinking Water Regulation the following parameters of the testing samples **210430745, 210430747, 210430748, 210430749, 210430750, 210430901, 210430902, 210430904, 210430905, 210430907 and 210430910** are out of limit value: **turbidity**

All other tested parameters are unobjectionable according to German Drinking Water Regulation as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, June 07, 2021

I. T. Andra