

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500731378
 Report 5344529 (June 2021)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	turbidity	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
210643775	Drinking water Delivery Tap 1	24.06.2021	09:15	20,4	colorless, clear	0,58	7,60	0,4	0	0	0	0	0	0
210643776	Drinking water Delivery Tap 2	24.06.2021	09:20	20,2	colorless, clear	0,66	7,56	0,3	0	0	0	0	0	0
210643777	Drinking water Delivery Tap 3	24.06.2021	09:10	20,0	colorless, clear	0,70	7,60	0,3	0	5	0	0	0	0
210643778	Drinking water Delivery Tap 4	24.06.2021	09:50	20,6	colorless, clear	0,80	7,60	0,4	0	0	0	0	0	0
210643779	Tank vehicle KWW 36, clutch pipe delivery	24.06.2021	-	-	-	-	-	-	sampling not possible: free chlorine >15 mg/l					
210643780	Tank vehicle KWW 38, clutch pipe delivery	24.06.2021	08:30	20,2	colorless, clear	0,50	7,80	0,2	0	0	0	0	0	0
210643781	Tank vehicle KWW 39, clutch pipe delivery	24.06.2021	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
210643783	Tank vehicle KWW 41, clutch pipe delivery	24.06.2021	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
210643784	Tank vehicle KWW 42, clutch pipe delivery	24.06.2021	-	-	-	-	-	-	sampling not possible: free chlorine >15 mg/l					
210643785	Tank vehicle KWW 43, clutch pipe delivery	24.06.2021	08:45	20,0	colorless, clear	0,62	7,60	0,4	0	3	0	0	0	0
210643786	Tank vehicle KWW 44, clutch pipe delivery	24.06.2021	08:30	20,0	colorless, clear	0,60	7,70	0,3	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



Report on the samples being taken by our field service - Your Order No.: BVD-4500731378
Report 5344529 (June 2021)

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	turbidity	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
210643787	Tank vehicle KWW 45, clutch pipe delivery	24.06.2021	-	-	-	-	-	-	-	-	-	-	-	-
210643788	Tank vehicle KWW 46, clutch pipe delivery	24.06.2021	08:35	20,4	colorless, clear	0,60	7,90	0,1	0	0	0	0	0	0
210643956	Tank vehicle KWW 47, clutch pipe delivery	24.06.2021	09:30	20,2	colorless, clear	0,80	7,90	0,2	0	0	0	0	0	0
210643957	Tank vehicle KWW 48, clutch pipe delivery	24.06.2021	08:35	21,6	colorless, clear	0,55	7,80	0,3	0	0	0	0	0	0
210643958	Tank vehicle KWW 49, clutch pipe delivery	24.06.2021	09:00	20,4	colorless, clear	0,56	7,50	0,1	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Tausenstein, June 29, 2021

