

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV)  
published on March 28th 2016, last changed on 3rd January 2018

## Fraport drinking water tank vehicles and delivery

Sampling date 12.12.2022

Mittwoch, 14. Dezember 2022

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100*	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-39 clutch pipe delivery	10,3	7,8	0,82	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	11,1	7,9	1,17	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	11,3	7,7	0,83	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	10,8	7,7	0,79	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	11,3	7,7	0,84	0	0	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	11,0	7,8	0,83	0	0	0	0	0	0
Tank vehicle KWW-47 clutch pipe delivery	11,2	8,0	1,10	0	0	0	0	0	0
Tank vehicle KWW-48 clutch pipe delivery	10,7	7,7	0,76	0	0	0	0	0	0
Tank vehicle KWW-50 clutch pipe delivery	10,7	7,7	0,83	0	1	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	11,0	7,7	0,91	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	10,3	7,6	0,91	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	11,2	7,5	0,64	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	11,1	7,8	1,20	0	0	0	0	0	0

\* Limit value for sample designations like "Übergabe Zapfstelle": 20 KBE

**Bemerkungen:**