

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
 report 5871831 (June 2022)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	Turbidity NTU	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 1°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
method				DIN 38404-4	DIN EN ISO 7887	DIN EN ISO 7393-2	DIN EN ISO 10523	DIN EN ISO 7027	pour plate method	pour plate method	DIN EN ISO 9308-2	DIN EN ISO 9308-2	ISO 16266-2	DIN EN ISO 7899-2
220581426	Drinking water Delivery Tap 1	24.06.2022	10:55	20,2	colorless, clear	0,46	7,50	< 0,1	0	0	0	0	0	0
220581427	Drinking water Delivery Tap 2	24.06.2022	11:05	20,0	colorless, clear	0,70	7,46	< 0,1	0	0	0	0	0	0
220581428	Drinking water Delivery Tap 3	24.06.2022	11:15	20,0	colorless, clear	0,54	7,40	< 0,1	0	0	0	0	0	0
220581429	Drinking water Delivery Tap 4	24.06.2022	11:30	20,4	colorless, clear	0,65	7,50	< 0,1	0	0	0	0	0	0
220581430	Tank vehicle KWW 36, clutch pipe delivery	24.06.2022	10:25	21,2	colorless, clear	1,40	7,60	< 0,1	0	0	0	0	0	0
220581431	Tank vehicle KWW 38, clutch pipe delivery	24.06.2022	-	-	-	-	-	-	-	-	-	-	-	-
220581432	Tank vehicle KWW 39, clutch pipe delivery	24.06.2022	-	-	-	-	-	-	-	-	-	-	-	-
220581434	Tank vehicle KWW 42, clutch pipe delivery	24.06.2022	10:45	24,0	colorless, clear	0,52	8,20	< 0,1	0	5	0	0	0	0
220581435	Tank vehicle KWW 43, clutch pipe delivery	24.06.2022	10:00	21,0	colorless, clear	1,12	7,50	< 0,1	1	0	0	0	0	0
220581438	Tank vehicle KWW 44, clutch pipe delivery	24.06.2022	10:30	23,4	colorless, clear	0,76	7,82	< 0,1	0	0	0	0	0	0
220581445	Tank vehicle KWW 45, clutch pipe delivery	24.06.2022	10:10	24,2	colorless, clear	0,76	7,80	< 0,1	0	0	0	0	0	0
220581446	Tank vehicle KWW 46, clutch pipe delivery	24.06.2022	-	-	-	-	-	-	-	-	-	-	-	-
220581447	Tank vehicle KWW 47, clutch pipe delivery	24.06.2022	10:40	22,2	colorless, clear	1,10	7,62	< 0,1	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
report 5871831 (june 2022)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	Turbidity NTU	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 1°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
220581449	Tank vehicle KVVV 49, clutch pipe delivery	24.06.2022	10:15	22,0	colorless, clear	1,00	7,60	< 0,1	0	0	0	0	0	0
220640224	Tank vehicle KVVV 41, clutch pipe delivery	24.06.2022	10:20	21,7	colorless, clear	1,10	7,60	< 0,1	0	0	0	0	0	0
220640225	Tank vehicle KVVV 48, clutch pipe delivery	24.06.2022	11:20	21,4	colorless, clear	1,00	7,60	< 0,1	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Tausenstein, July, 07, 2022



The laboratory sites of the SGS group Germany according to the abbreviations mentioned above including the corresponding accreditation process numbers are listed at <http://www.institut-fresenius.de/filestore/89/labstandortkuerzetsgs.pdf>.

*** End of test report ***

This document is issued by the Company subject to its General Conditions of Service (www.sgs.com/de/sgb). Attention is drawn to the limitations of liability, indemnification and jurisdictional issues established therein. This document is an original. If the document is submitted digitally, it is to be treated as an original within the meaning of UCP 600. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of client's instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.