

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500648363  
report 6057247 (october 2022)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	Turbidity NTU	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 1°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
method				DIN 38404-4 1976-12	DIN EN ISO 7887 2012-04	DIN EN ISO 7393-2 2004-04	DIN EN ISO 10523 2012-04	DIN EN ISO 7027 2016-11	TrinkwV § 15 Absatz (1c) 2018-01	TrinkwV § 15 Absatz (1c) 2018-01	DIN EN ISO 9308-2 2014-6	DIN EN ISO 9308-2 2014-6	ISO 16286-2 2018-07	DIN EN ISO 7899-2 2000-11
221073784	Drinking water Delivery Tap 1	31.10.2022	07:50	16,2	colorless, clear	0,76	7,40	< 0,1	0	0	0	0	0	0
221073935	Drinking water Delivery Tap 2	31.10.2022	08:00	15,8	colorless, clear	1,00	7,50	< 0,1	0	0	0	0	0	0
221073936	Drinking water Delivery Tap 3	31.10.2022	08:15	16,0	colorless, clear	0,76	7,50	< 0,1	0	0	0	0	0	0
221073937	Drinking water Delivery Tap 4	01.11.2022	07:40	16,4	colorless, clear	0,58	7,24	< 0,1	0	0	0	0	0	0
221073943	Tank vehicle KWW 36, clutch pipe delivery	31.10.2022	09:25	15,7	colorless, clear	0,62	7,72	0,1	0	0	0	0	0	0
221073944	Tank vehicle KWW 36, clutch pipe delivery	31.10.2022	08:40	15,8	colorless, clear	0,74	7,70	< 0,1	0	0	0	0	0	0
221073945	Tank vehicle KWW 39, clutch pipe delivery	31.10.2022	09:15	15,8	colorless, clear	0,94	7,60	< 0,1	0	0	0	0	0	0
221073946	Tank vehicle KWW 41, clutch pipe delivery	31.10.2022	09:30	15,8	colorless, clear	0,50	7,76	0,1	0	0	0	0	0	0
221073947	Tank vehicle KWW 42, clutch pipe delivery	31.10.2022	08:45	16,2	colorless, clear	0,75	7,58	< 0,1	0	0	0	0	0	0
221073948	Tank vehicle KWW 43, clutch pipe delivery	31.10.2022	09:45	16,2	colorless, clear	0,44	7,28	< 0,1	0	0	0	0	0	0
221073949	Tank vehicle KWW 44, clutch pipe delivery	31.10.2022	-	-	-	-	-	-	<b>sampling not possible: tank vehicle in repair shop</b>					0
221073950	Tank vehicle KWW 45, clutch pipe delivery	31.10.2022	08:50	16,4	colorless, clear	0,45	7,66	< 0,1	0	0	0	0	0	0
221074001	Tank vehicle KWW 46, clutch pipe delivery	31.10.2022	-	-	-	-	-	-	<b>sampling not possible: tank vehicle in repair shop</b>					0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500648363  
report 6057247 (October 2022)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	Turbidity NTU	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 1°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
221074002	Tank vehicle KWW 47, clutch pipe delivery	31.10.2022	09:20	17,2	colorless, clear	0,55	7,72	< 0,1	0	0	0	0	0	0
221074003	Tank vehicle KWW 48, clutch pipe delivery	31.10.2022	09:00	16,6	colorless, clear	0,60	7,66	< 0,1	0	0	0	0	0	0
221074004	Tank vehicle KWW 49, clutch pipe delivery	31.10.2022	-	-	-	-	-	-	<b>sampling not possible: tank vehicle in repair shop</b>					
221193559	Tank vehicle KWW 50, clutch pipe delivery	31.10.2022	09:00	16,1	colorless, clear	0,54	7,60	0,1	1	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Tausenstein, november, 09, 2022



The laboratory sites of the SGS group Germany according to the abbreviations mentioned above including the corresponding accreditation process numbers are listed at <http://www.institut-fresenius.de/filestore/89/laborstandortkuerzseigs.pdf>.

\*\*\* End of test report \*\*\*

This document is issued by the Company subject to its General Conditions of Service ([www.sgs.com](http://www.sgs.com)). Attention is drawn to the limitations of liability, indemnification and jurisdictional issues established therein. This document is an original. If the document is submitted digitally, it is to be treated as an original within the meaning of UCP 600. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of clients' instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.