

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500648363
report 5706604 (february 2022)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	Turbidity NTU	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 1°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
method				DIN 38404-4	DIN EN ISO 7887	DIN EN ISO 7393-2	DIN EN ISO 10523	DIN EN ISO 7027	pour plate method	pour plate method	DIN EN ISO 9308-2	DIN EN ISO 9308-2	ISO 16266-2	DIN EN ISO 7899-2
220074982	Drinking water Delivery Tap 1	28.02.2022	09:55	7,0	colorless, clear	0,68	7,34	< 0,1	0	0	0	0	0	0
220074985	Drinking water Delivery Tap 2	28.02.2022	09:35	9,8	colorless, clear	0,80	7,72	< 0,1	0	0	0	0	0	0
220074986	Drinking water Delivery Tap 3	28.02.2022	09:15	10,0	colorless, clear	0,64	7,56	0,30	0	0	0	0	0	0
220074987	Drinking water Delivery Tap 4	28.02.2022	08:50	10,8	colorless, clear	0,36	7,50	< 0,1	0	0	0	0	0	0
220074988	Tank vehicle KWW 36, clutch pipe delivery	28.02.2022	09:25	9,6	colorless, clear	0,60	7,74	< 0,1	0	0	0	0	0	0
220074989	Tank vehicle KWW 38, clutch pipe delivery	28.02.2022	09:45	9,0	colorless, clear	0,60	7,80	< 0,1	0	0	0	0	0	0
220074990	Tank vehicle KWW 39, clutch pipe delivery	28.02.2022	09:28	16,6	colorless, clear	0,40	7,60	-	0	0	0	0	0	0
220074991	Tank vehicle KWW 41, clutch pipe delivery	28.02.2022	09:30	9,2	colorless, clear	0,66	7,80	< 0,1	0	0	0	0	0	0
220075059	Tank vehicle KWW 42, clutch pipe delivery	28.02.2022	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
220075061	Tank vehicle KWW 43, clutch pipe delivery	28.02.2022	09:24	9,0	colorless, clear	0,64	7,72	< 0,1	0	0	0	0	0	0
220075062	Tank vehicle KWW 44, clutch pipe delivery	28.02.2022	09:00	16,5	colorless, clear	0,62	7,60	< 0,1	0	0	0	0	0	0

