

**Monitoring of water supply systems by the health department in accordance with § 54 ff. german drinking water regulations (TrinkwV)**
**Fraport drinking water tank vehicles and delivery**
**Sampling date 29.06.2023**

Montag, 3. Juli 2023

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100*	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-36 clutch pipe delivery	21,8	7,9	0,61	0	1	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	20,9	7,8	0,64	0	2	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	21,7	7,9	0,67	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	23,2	8,0	0,14	0	208	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	22,6	8,0	0,65	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	22,4	8,0	0,62	1	3	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	22,0	8,0	0,65	1	0	0	0	0	0
Tank vehicle KWW-46 clutch pipe delivery	20,7	7,8	0,67	0	0	0	0	0	0
Tank vehicle KWW-47 clutch pipe delivery	22,5	7,9	0,65	0	0	0	0	0	0
Tank vehicle KWW-48 clutch pipe delivery	21,4	7,8	0,68	0	1	0	0	0	0
Tank vehicle KWW-49 clutch pipe delivery	22,0	7,9	0,75	0	2	0	0	0	0
Tank vehicle KWW-50 clutch pipe delivery	21,7	8,1	0,65	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	19,6	8,2	0,96	0	1	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	19,5	7,8	0,89	0	2	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	19,6	7,9	0,73	0	2	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	20,3	7,6	0,95	0	2	0	0	0	0

\* Limit value for sample designations like "Übergabe Zapfstelle": 20 KBE

**Bemerkungen:**