

**Monitoring of water supply systems by the health department in accordance with § 54 ff. german drinking water regulations (TrinkwV)**
**Fraport Wassertransportfahrzeuge**
**Sampling date 12.12.2023**

Donnerstag, 14. Dezember 2023

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100*	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-38 clutch pipe delivery	10,8	7,8	0,62	0	1	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	10,5	8,1	0,71	0	2	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	11,6	7,8	0,84	0	2	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	10,9	8,0	0,76	0	1	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	11,1	7,8	0,77	0	3	0	0	0	0
Tank vehicle KWW-46 clutch pipe delivery	10,6	7,9	0,67	0	0	0	0	0	0
Tank vehicle KWW-47 clutch pipe delivery	11,5	8,0	0,37	0	0	0	0	0	0
Tank vehicle KWW-48 clutch pipe delivery	11,1	7,9	0,65	0	1	0	0	0	0
Tank vehicle KWW-49 clutch pipe delivery	11,0	7,8	0,65	0	3	0	0	0	0
Tank vehicle KWW-50 clutch pipe delivery	12,0	7,9	0,74	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	10,7	7,9	0,70	0	1	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	10,6	7,9	0,63	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	10,4	7,8	0,75	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	10,5	7,9	0,85	0	0	0	0	0	0

\* Limit value for sample designations like "Übergabe Zapfstelle": 20 KBE

**Bemerkungen:**