



To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500790807
report 6368483 (may 2023)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	Turbidity NTU	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 1°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
method					DIN EN ISO 7887 2012-04	DIN EN ISO 7393-2 2004-04	DIN EN ISO 10523 2012-04	DIN EN ISO 7027 2016-11	TrinkwV § 15 Absatz (1c) 2018-01	TrinkwV § 15 Absatz (1c) 2018-01	DIN EN ISO 9308-2 2014-6	DIN EN ISO 9308-2 2014-6	ISO 16266-2 2018-07	DIN EN ISO 7899-2 2000-11
230425816	Drinking water Delivery Tap 1	31.05.2023	09:45	17,0	colorless, clear	0,78	8,10	0,3	0	0	0	0	0	0
230425817	Drinking water Delivery Tap 2	31.05.2023	09:55	17,1	colorless, clear	0,95	8,01	0,3	0	0	0	0	0	0
230425818	Drinking water Delivery Tap 3	31.05.2023	10:45	17,0	colorless, clear	0,86	7,95	0,3	0	0	0	0	0	0
230425819	Drinking water Delivery Tap 4	31.05.2023	-	-	-	-	-	-	sampling not possible: defective dispensing					
230425820	Tank vehicle KWW 36, clutch pipe delivery	31.05.2023	10:00	18,7	colorless, clear	0,68	8,21	0,3	0	0	0	0	0	0
230425863	Tank vehicle KWW 38, clutch pipe delivery	31.05.2023	09:20	19,0	colorless, clear	0,66	8,13	0,4	0	0	0	0	0	0
230425865	Tank vehicle KWW 39, clutch pipe delivery	31.05.2023	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
230425867	Tank vehicle KWW 41, clutch pipe delivery	31.05.2023	08:20	17,5	colorless, clear	0,85	7,82	0,3	0	0	0	0	0	0
230425868	Tank vehicle KWW 42, clutch pipe delivery	31.05.2023	10:20	19,3	colorless, clear	0,67	8,23	0,4	0	0	0	0	0	0
230425869	Tank vehicle KWW 43, clutch pipe delivery	31.05.2023	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
230425870	Tank vehicle KWW 44, clutch pipe delivery	31.05.2023	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
230425871	Tank vehicle KWW 45, clutch pipe delivery	31.05.2023	09:30	19,5	colorless, clear	0,48	8,10	0,3	0	0	0	0	0	0
230425872	Tank vehicle KWW 46, clutch pipe delivery	31.05.2023	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					



To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500790807
report 6368483 (may 2023)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	Turbidity NTU	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 1°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
230425873	Tank vehicle KWW 47, clutch pipe delivery	31.05.2023	08:56	18,4	colorless, clear	0,72	8,17	0,3	0	0	0	0	0	0
230425875	Tank vehicle KWW 48, clutch pipe delivery	31.05.2023	08:40	19,4	colorless, clear	0,62	8,13	0,4	0	0	0	0	0	0
230425876	Tank vehicle KWW 49, clutch pipe delivery	31.05.2023	10:10	20,9	colorless, clear	0,69	8,13	0,3	0	0	0	0	0	0
230425877	Tank vehicle KWW 50, clutch pipe delivery	31.05.2023	08:30	18,2	colorless, clear	0,65	7,96	0,3	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH Tausnusstein, June 5th, 2023

The laboratory sites of the SGS group Germany according to the abbreviations mentioned above including the corresponding accreditation process numbers are listed at <http://www.institut-fresenius.de/filestore/69/aborstandortkuerzelsgs.pdf>.

*** End of test report ***

This document is issued by the Company subject to its General Conditions of Service (www.sgs-group.de/legb). Attention is drawn to the limitations of liability, indemnification and jurisdictional issues established therein. This document is an original. If the document is submitted digitally, it is to be treated as an original within the meaning of UCP 600. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of client's instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.