

Monitoring of water supply systems by the health department in accordance with § 54 ff. german drinking water regulations (TrinkwV)
Fraport Wassertransportfahrzeuge
Sampling date 31.10.2023

Dienstag, 7. November 2023

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100*	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-38 clutch pipe delivery	13,2	8,0	0,51	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	14,7	7,7	0,80	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	13,2	8,0	0,67	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	13,4	8,2	0,65	0	1	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	13,7	8,1	0,67	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	13,7	7,7	0,79	0	0	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	13,9	8,1	0,72	0	0	0	0	0	0
Tank vehicle KWW-48 clutch pipe delivery	14,5	7,8	0,73	0	0	0	0	0	0
Tank vehicle KWW-49 clutch pipe delivery	13,1	7,8	0,60	0	0	0	0	0	0
Tank vehicle KWW-50 clutch pipe delivery	13,6	7,9	0,70	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	14,9	7,7	0,97	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	15,0	7,8	1,23	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	15,1	7,7	1,14	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	14,7	7,8	1,07	0	0	0	0	0	0

* Limit value for sample designations like "Übergabe Zapfstelle": 20 KBE

Bemerkungen: