



To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500790807
report 6449787 (July 2023)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	Turbidity NTU	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 1°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
230647866	Drinking water Delivery Tap 1	10.07.2023	11:10	20,2	colorless, clear	0,97	7,55	0,3	Trinkwv § 15 Absatz (1c) 2018-01	Trinkwv § 15 Absatz (1c) 2018-01	DIN EN ISO 9308-2 2014-6	DIN EN ISO 9308-2 2014-6	ISO 16266-2 2018-07	DIN EN ISO 7899-2 2000-11
230647867	Drinking water Delivery Tap 2	10.07.2023	11:00	19,9	colorless, clear	0,99	7,55	<0,1	0	0	0	0	0	0
230647868	Drinking water Delivery Tap 3	10.07.2023	10:55	20,0	colorless, clear	0,94	7,58	<0,1	0	0	0	0	0	0
230647869	Drinking water Delivery Tap 4	10.07.2023	10:40	20,0	colorless, clear	0,92	7,71	<0,1	0	0	0	0	0	0
230647870	Tank vehicle KWW 36, clutch pipe delivery	10.07.2023	-	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
230647871	Tank vehicle KWW 38, clutch pipe delivery	10.07.2023	10:24	25,1	colorless, clear	0,70	7,98	<0,1	0	0	0	0	0	0
230647873	Tank vehicle KWW 39, clutch pipe delivery	10.07.2023	09:43	23,8	colorless, clear	0,71	7,86	0,4	0	0	0	0	0	0
230647875	Tank vehicle KWW 41, clutch pipe delivery	10.07.2023	10:30	27,2	colorless, clear	0,57	7,88	<0,1	0	0	0	0	0	0
230647877	Tank vehicle KWW 42, clutch pipe delivery	10.07.2023	08:36	20,3	colorless, clear	0,88	7,65	0,4	0	0	0	0	0	0
230647880	Tank vehicle KWW 43, clutch pipe delivery	10.07.2023	09:20	29,8	colorless, clear	0,41	7,80	0,1	0	0	0	0	0	0
230647882	Tank vehicle KWW 44, clutch pipe delivery	10.07.2023	08:48	22,9	colorless, clear	0,78	7,64	0,1	0	0	0	0	0	0
230647886	Tank vehicle KWW 45, clutch pipe delivery	10.07.2023	09:37	24,4	colorless, clear	0,79	7,91	0,3	0	0	0	0	0	0
230647888	Tank vehicle KWW 46, clutch pipe delivery	10.07.2023	09:52	25,9	colorless, clear	0,63	7,96	0,1	0	0	0	0	0	0



To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500790807
report 6449787 (July 2023)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	Turbidity NTU	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 1°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
230647893	Tank vehicle KWW 47, clutch pipe delivery	10.07.2023	10:00	22,9	colorless, clear	0,74	7,81	0,4	0	0	0	0	0	0
230647895	Tank vehicle KWW 48, clutch pipe delivery	10.07.2023	08:56	24,5	colorless, clear	0,73	7,89	0,4	0	0	0	0	0	0
230647897	Tank vehicle KWW 49, clutch pipe delivery	10.07.2023	08:25	22,0	colorless, clear	0,75	7,56	0,1	0	0	0	0	0	0
230647900	Tank vehicle KWW 50, clutch pipe delivery	10.07.2023	09:27	24,7	colorless, clear	0,75	7,99	0,3	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Tausenstein, July 27th, 2023

i. A. G. Schätzel

The laboratory sites of the SGS group Germany according to the abbreviations mentioned above including the corresponding accreditation process numbers are listed at <http://www.institut-fresenius.de/filestore/89/laborstandortkuerzelsgs.pdf>.

*** End of test report ***

This document is issued by the Company subject to its General Conditions of Service (www.sgsgroup.de/aggb). Attention is drawn to the limitations of liability, indemnification and jurisdictional issues established therein. This document is an original. If the document is submitted digitally, it is to be treated as an original within the meaning of UCP 600. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of client's instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.