

**Monitoring of water supply systems by the health department in accordance with § 54 ff. german drinking water regulations (TrinkwV)**

**Fraport Wassertransportfahrzeuge**

Sampling date 26.03.2024

Dienstag, 2. April 2024

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100*	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-38 clutch pipe delivery	11,0	8,0	0,47	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	10,7	7,8	0,59	0	1	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	9,9	7,9	0,60	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	10,4	7,9	0,50	0	0	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	10,5	7,7	0,74	0	0	0	0	0	0
Tank vehicle KWW-46 clutch pipe delivery	8,7	7,8	0,61	0	1	0	0	0	0
Tank vehicle KWW-47 clutch pipe delivery	10,2	7,9	0,48	0	0	0	0	0	0
Tank vehicle KWW-48 clutch pipe delivery	12,7	7,6	0,88	0	0	0	0	0	0
Tank vehicle KWW-49 clutch pipe delivery	10,8	7,9	0,62	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	11,7	7,8	0,45	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	11,7	7,7	0,57	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	9,3	7,0	0,71	0	0	0	0	0	0

\* Limit value for sample designations like "Übergabe Zapfstelle": 20 KBE

**Bemerkungen:**