



To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500790807  
report 6723188 (January 2024)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	Turbidity NTU	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 1°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
method				DIN 38404-4 1976-12	DIN EN ISO 7887 2012-04	DIN EN ISO 7393-2 2004-04	DIN EN ISO 10523 2012-04	DIN EN ISO 7027 2016-11	Trinkwv § 43 Absatz (3.2) 2023-06	Trinkwv § 43 Absatz (3.2) 2023-06	DIN EN ISO 9308-2 2014-6	DIN EN ISO 9308-2 2014-6	ISO 16286-2 2018-07	DIN EN ISO 7899-2 2000-11
240007312	Drinking water Delivery Tap 1	29.01.2024	08:40	8,8	colorless, clear	0,61	7,91	0,3	0	0	0	0	0	0
240007314	Drinking water Delivery Tap 2	29.01.2024	08:45	8,7	colorless, clear	0,91	7,89	0,3	0	0	0	0	0	0
240007315	Drinking water Delivery Tap 3	29.01.2024	10:55	9,2	colorless, clear	0,98	7,69	0,4	0	0	0	0	0	0
240007316	Drinking water Delivery Tap 4	29.01.2024	11:15	8,9	colorless, clear	0,87	7,72	0,4	0	0	0	0	0	0
240007317	Tank vehicle KWW 36, clutch pipe delivery	29.01.2024	10:20	12,3	colorless, clear	0,33	7,48	0,2	0	0	0	0	0	0
240007331	Tank vehicle KWW 38, clutch pipe delivery	29.01.2024	09:35	7,9	colorless, clear	0,73	7,85	0,2	0	0	0	0	0	0
240007332	Tank vehicle KWW 39, clutch pipe delivery	29.01.2024	11:30	12,9	colorless, clear	0,58	7,65	0,3	0	0	0	0	0	0
240007333	Tank vehicle KWW 41, clutch pipe delivery	29.01.2024	10:40	12,2	colorless, clear	0,60	7,79	1,3	1	2	0	0	0	0
240007336	Tank vehicle KWW 42, clutch pipe delivery	29.01.2024	10:05	8,1	colorless, clear	0,74	7,75	0,2	0	0	0	0	0	0
240007337	Tank vehicle KWW 43, clutch pipe delivery	29.01.2024	09:20	7,9	colorless, clear	0,71	7,91	0,3	0	0	0	0	0	0
240007338	Tank vehicle KWW 44, clutch pipe delivery	29.01.2024	09:25	8,2	colorless, clear	0,82	7,71	0,3	0	0	0	0	0	0
240007339	Tank vehicle KWW 45, clutch pipe delivery	29.01.2024	09:40	7,5	colorless, clear	0,64	7,76	0,3	3	1	0	0	0	0
240007340	Tank vehicle KWW 46, clutch pipe delivery	29.01.2024	10:15	7,6	colorless, clear	0,76	7,62	0,2	0	0	0	0	0	0



To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500790807  
report 6723188 (January 2024)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	Turbidity NTU	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 1°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
240007341	Tank vehicle KWW 47, clutch pipe delivery	29.01.2024	09:05	9,8	colorless, clear	0,71	7,69	0,5	0	0	0	0	0	0
240007342	Tank vehicle KWW 48, clutch pipe delivery	29.01.2024	09:50	8,6	colorless, clear	0,77	7,90	0,5	0	0	0	0	0	0
240007344	Tank vehicle KWW 49, clutch pipe delivery	29.01.2024	09:15	7,7	colorless, clear	0,72	7,48	0,4	0	0	0	0	0	0
240007345	Tank vehicle KWW 50, clutch pipe delivery	29.01.2024	10:00	8,3	colorless, clear	0,79	7,80	0,5	0	0	0	0	0	0

**Assessment:**

According to the investigations of the German Drinking Water Regulation the following parameter of the testing sample **240007333** is out of limit value: **Turbidity**

The quality of all other tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Tausenstein, February 05<sup>th</sup>, 2024

The laboratory sites of the SGS group Germany according to the abbreviations mentioned above including the corresponding accreditation process numbers are listed at <http://www.institut-fresenius.de/filestore/89/labstandortkuerzelsgs.pdf>.

\*\*\* End of test report \*\*\*

This document is issued by the Company subject to its General Conditions of Service ([www.sgsgroup.de/egb](http://www.sgsgroup.de/egb)). Attention is drawn to the limitations of liability, indemnification and jurisdictional issues established therein. This document is an original. If the document is submitted digitally, it is to be treated as an original within the meaning of UCP 600. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of client's instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.